s for contamination of the HRMA

Molecular contamination

AXAF Project Science

AXAF XRCF Pre-Calibration Review

NASA Marshall Space Flight Center

1996 November 13-15

Summary

contamination can alter HRMA performance.
ance of hydrocarbon differs from that of iridium.
nge in effective area is as high as 0.5% (I_{hc}/Å).
nost energies, hydrocarbon contamination increases
ctive area.
nge in effective area is most pronounced at Ir-M_V edge.
t-like molecular contamination scatters like particulates

st for molecular contamination is an SSD measurement of the
ective area of each HRMA shell.

tests are parasitic or conditional.
spectra could probe properties of contamination.
ctra would show details of Ir-M_V edge.
ctra might show atomic edges of contaminants.
easurements of HRMA-subaperture effective areas could
azimuthal location of detected molecular contamination.

Primary test

XSS source is the Electron Impact Point Source (EIPS).
(C) anode is at 15 kV, with 1.5% bias and 0.4 mA current.
wheel position is for the beryllium τ=2 [BeK2] filter.
monitor detector is the Building-500 Solid-State Detector SSD_5.
g time constant is set to 2 μs for up to 10,000 ct/s.
ed aperture diameter is the 5 mm (no Al filter).
e detector is the Solid-State Detector SSD_X.
g time constant is set to 2 μs for up to 10,000 ct/s.
ed aperture diameter is the 5 mm (no Al filter).
HRMA for spectrometric effective-area measurement.
TGs.
ntially set HRMA shutters to obtain 300-s SSD spectra for
RMA shell.

ffective area of HRMA with hydrocarbon layer





ea (A_{eff}) of the HRMA for various thicknesses of a hydrocarbon film. The (l) the effective area and (r) the effective-area ratio for hydrocarbon $_{hc}$) ranging from 0 Å to 50 Å, in 5-Angstrom increments.

tive area of HRMA shell 1 with hydrocarbon layer





ea (A_{eff}) of the HRMA shell 1 for various thicknesses of a hydrocarbon film. show (l) the effective area and (r) the effective-area ratio for hydrocarbon $_{hc}$) ranging from 0 Å to 50 Å, in 5-Angstrom increments.

tive area of HRMA shell 3 with hydrocarbon layer





ea (A_{eff}) of the HRMA shell 3 for various thicknesses of a hydrocarbon film. show (l) the effective area and (r) the effective-area ratio for hydrocarbon $_{hc}$) ranging from 0 Å to 50 Å, in 5-Angstrom increments.

tive area of HRMA shell 4 with hydrocarbon layer





ea (A_{eff}) of the HRMA shell 4 for various thicknesses of a hydrocarbon film.
show (l) the effective area and (r) the effective-area ratio for hydrocarbon
$_{hc}$) ranging from 0 Å to 50 Å, in 5-Angstrom increments.

tive area of HRMA shell 6 with hydrocarbon layer



ea (A_{eff}) of the HRMA shell 6 for various thicknesses of a hydrocarbon film. show (l) the effective area and (r) the effective-area ratio for hydrocarbon $_{hc}$) ranging from 0 Å to 50 Å, in 5-Angstrom increments.

...ination sensitivity measurement for HRMA shell 1



...300-s contamination sensitivity measurement for HRMA shell 1. The plots ...SD_X pulse-height spectrum for 0-Å hydrocarbon layer, the spectrum for 10-...bon layer, and the ratio. Each bin is 4 SSD channels or 19.5 eV.

...nination sensitivity measurement for HRMA shell 3



...300-s contamination sensitivity measurement for HRMA shell 3. The plots ...SD_X pulse-height spectrum for 0-Å hydrocarbon layer, the spectrum for 10-...bon layer, and the ratio. Each bin is 4 SSD channels or 19.5 eV.

ination sensitivity measurement for HRMA shell 4



300-s contamination sensitivity measurement for HRMA shell 4. The plots SD_X pulse-height spectrum for 0-Å hydrocarbon layer, the spectrum for 10-bon layer, and the ratio. Each bin is 4 SSD channels or 19.5 eV.

nination sensitivity measurement for HRMA shell 6



300-s contamination sensitivity measurement for HRMA shell 6. The plots SD_X pulse-height spectrum for 0-Å hydrocarbon layer, the spectrum for 10-bon layer, and the ratio. Each bin is 4 SSD channels or 19.5 eV.

Effective area measurement for HRMA shell 1



300-s effective-area (A_{eff}) measurement for HRMA shell 1. The plots show pulse-height spectrum, the SSD_5 pulse-height spectrum, and the ratio. 4 SSD channels or 19.5 eV. The shell-1 A_{eff} is 44.2 cm^2 times the ratio.

ffective area measurement for HRMA shell 3



300-s effective-area (A_{eff}) measurement for HRMA shell 3. The plots show pulse-height spectrum, the SSD_5 pulse-height spectrum, and the ratio. 4 SSD channels or 19.5 eV. The shell-3 A_{eff} is 44.2 cm^2 times the ratio.

Effective area measurement for HRMA shell 4



300-s effective-area (A_{eff}) measurement for HRMA shell 4. The plots show pulse-height spectrum, the SSD_5 pulse-height spectrum, and the ratio. 4 SSD channels or 19.5 eV. The shell-4 A_{eff} is 44.2 cm^2 times the ratio.

Effective area measurement for HRMA shell 6



300-s effective-area (A_{eff}) measurement for HRMA shell 6. The plots show pulse-height spectrum, the SSD_5 pulse-height spectrum, and the ratio. 4 SSD channels or 19.5 eV. The shell-6 A_{eff} is 44.2 cm^2 times the ratio.